

Test Report No. <u>2859/16</u> Sassuolo, 23/03/16

Requested by: COTTO		D'ESTE - Via Emilia Romagna, 31 – 41049 SASSUOLO (MO)	
For the sample: Ceramic ti		tiles 60 x 60 x 1,4 cm marked "Unglazed ceramic tiles – Serie SECRET STONE GRIP".	
On (date): 29/02/16		Date of receipt in laboratory (sample delivered by the client): 01/03/16	
Test date		From: 02/03/16	To: 02/03/16

DIN 51130 (06/2004) - Determination of the anti - slip properties Workrooms and fields of activities with raised slip danger, walking method - ramp test Surface characteristics Smooth Profiled Structured Rough **RESULTS** Average total acceptance angle: 25,2° Movement area (cm³/dm²): **CLASSIFICATION (BGR 181 – 10/2003) R11** Group of anti - slip properties: Movement area evaluation group: Eng. Giordana Caran Technical app Prof. Maria Chiara Bignozzi

The results reported relate only to the samples tested. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction. This test report consists of 1 pages, this cover included.

Director